


VIDEO EXTENSOMETRY FOR MATERIAL TESTING

ISO9513 Compliant to Class 1 & Class 0.5 Accuracy

Applicable to High-Temperature and Climate-Chamber Measurements

MATERIAL SAMPLE MEASUREMENTS



SIMPLE VISUAL TOOLS FOR QUICK MEASUREMENT

LINE



An elementary measuring probe for strain and length determination.

TRANS LINE



Offers a multi-positional transversal measurement with averaged and max/min width functions.



Measures a crack length during static or dynamic tests.

EXTREME LINE



An advanced probe for axial neck detection. Provides an improved E-modulus reading and minimizes the occurrence of invalid tests caused by rupturing outside the gauge length area.

BEND LINE



A probe designed to be used during bending tests. Measures strain over a curved shape and enables the visualization of the strain distribution in real-time.

LINE STRAIN DISTRIBUTION



Provides a colorful strain visualization feature during real-time measurement.



Enables dual position angular twist and strain measurement.

POINT



A basic measuring probe for displacement determination.

DIC AREA




A full-field probe for strain and displacement distribution mapping.



MATERIAL TESTING DEVICES

ONE

Smart and easy. The compact video extensometer for static and quasi-static experiments. The devices are stackable. For longer specimen, two or three ONEs can be mounted next to or on top of each other.



STEREO ONE

A 3D-functionality enhancement of X-Sight's top-selling industrial measuring device provides the opportunity to measure specimens with complex geometry or specimens displaying large out-of-plane displacement during testing.



HT

HT is designed for high-temperature applications. Equipped with a telecentric lens and a high-resolution camera, it provides a very fine strain reading.



ROD

ROD is specially optimized for tensile testing of reinforcing steel. The advanced functionality of the Alpha software allows to measure specimen with an oxide or rust layer, falling off significantly, making the use of standard video extensometers almost impossible.

